



ALBUQUERQUE FIRE DEPARTMENT PREAPPROVED TENT FLOOR PLANS

EVENT _____	VENDOR NAME _____	FLOOR PLAN # _____
PRINTED NAME _____	SIGNATURE _____	

Tent requirements:

- The tent shall meet one of the following flame retardant standards.
 - CPA184
 - NFPA 701
 - California fire retardant standards
- Each tent shall have one no smoking sign conspicuously located
- Each tent shall be anchored to withstand the elements of weather and prevent collapse.
- The tent frame and membrane shall be free of combustible materials.
- The tent frame shall not be used to brace, hang, support any objects. Exception: tent membrane, fire extinguisher
- All display grids and display racks shall be noncombustible or flame treated, preferably constructed out of metal.

Pick one of the preapproved floor plans and mark your selection above.

